


NOTES:

1. TRENCH ALIGNMENT IS DETERMINED BY THE RIGHT-OF-WAY AND OR EASEMENTS.
2. MINIMUM TRENCH WIDTH 6" AND MUST PROVIDE A MINIMUM OF 36" OF COVER AND A MAXIMUM OF 48".
3. THE BOTTOM OF THE TRENCH MUST BE SMOOTH AND CONTINUOUS.
4. ALL TRENCH MUST REMAIN OPEN UNTIL INSPECTED BY LPC.
5. MARKER RIBBON TO BE INSTALLED BEFORE FINAL 12".
6. 95% COMPACTION IS REQUIRED TO A POINT 12" BELOW FINAL GRADE AND 90% FOR THE LAST 12".

	TRENCH DETAIL		
	REV.	700-04	SCALE: NA
POWER & COMMUNICATIONS	DATE: DECEMBER 2003	DRAWN BY: RAWTF	APPROVAL: